

Addendum 1 (Page 1 of 1)
Request for Proposal FY17-0214 Indoor Warning System

Addendum No. 1 (herein referred to as "Addendum")

This Addendum revises the above-described procurement, and is hereby incorporated and made a part of the above-described procurement as if the Addendum had been included in the original procurement documents. Addendum posted on website at www.orangburgcounty.org-Procurement.

This addendum is as follows: Questions/Responses (See Red) – January 31, 2017

The attached Site plans will provide the building layouts for the Administration Center 42,756 Square Feet, Courthouse 44,160 Square Feet and the Magistrate Building 7,900. **Site plans will be posted as an Addendum.**

The following questions should be answered as followed.

1. Do we have floor plans for the buildings?
 - a. **The floor plans are attached.**
2. What fire alarm systems are currently in the buildings?
 - a. **All buildings should have A Simplex Grinnell Fire Alarms System.**
3. Are the buildings connected by fiber?
 - a. **Yes**
4. Do you have an LMR2-way radio channel to be used for activation of the systems?
 - a. **No**
5. Is this a turnkey project?
 - a. **yes**
6. Does the system need to communicate between buildings?
 - a. **They do not need to talk to each other.**
7. The specifications call for local control of the system. Where will that local control be initiated from? (Building?) If that building is defined will there be room in this building for a computer with monitor and possibly a radio?
 - a. **Local Control should be able to be done from the building the alarms system is located in. There will be room for a computer and radio.**
8. Will the activation facility have 120 VAC power available for use such as a wall plug?
 - a. **yes**
9. Will Internet be available for the activation computer requested in the bid?
 - a. **yes**
10. Will the activation site have a power back up system already?
 - a. **No**
11. Are there any restrictions on what type pole can be used for the Warning Siren for your facility? (as standard a wooden pole is used)

- a. There are no restrictions on the pole, however, the county is requesting a system that will give audible instructions on the warning and actions to be taken by the public.
- 12. If the warning siren is need to be in a different location than the activation site will a radio frequency be available for signaling the siren for activation? If so, what will the frequency be?
 - a. The warning system should be located at the activation site.
- 13. Are the buildings on the same campus?
 - a. The buildings are not on the same campus. The address area as follows.
 - i. Orangeburg County Administration Center , 1437 Amelia Street, Orangeburg, SC, 29115
 - ii. Orangeburg County Courthouse, 151 Dockett, Orangeburg, SC, 29115
 - iii. Orangeburg County magistrate Building, 1540 Ellis Ave, Orangeburg, SC, 29115