

Addendum 1 (Page 1 of 1)
Request for Proposal FY17-0310 Roof Replacement- Edisto Senior Community Center

Addendum No.1 (herein referred to as "Addendum")

This Addendum revises the above-described procurement, and is hereby incorporated and made a part of the above-described procurement as if the Addendum had been included in the original procurement documents. Addendum posted on website at www.orangburgcounty.org-Procurement.

This addendum is as follows: Questions/Responses (See Red) – February 28, 2017

- 1) Are any of the existing rolled flat roofs to be included in the bid? **No**

- 2) There is an area on the rear that is propped up by a pipe and a piece of wood....does that piece of fascia and soffit need to be included in the bid price? **No**

- 3) Nearly 2/3 of the shingled portion of the roof has a 1/12 slope and shingles are not recommended by any manufacturer in these areas. **For the areas less than 2/12 slope, an equivalent manufacturer recommended product for that application shall be used.**

Failure to acknowledge addendum in proposal submission document can cause for disqualification.